



UNITED

BATCH # :

L A B O R A T O R I E S

EARTH SMART® FORMULATION:

- 8-strain blend includes the cold-weather strain.
- High bacteria count (5 billion CFU/gm).
- Will not harm humans, birds, fish or plant life.
- Safe on pipes, pumps, and other equipment.
- No hazardous components.
- Active working pH range 6-9.
- Works at temperatures between 38°F and 100°F.
- Does not produce hydrogen sulfide.
- Reduces and eliminates grease layers on ponds and lagoons.
- Reduces heavy BOD loadings in secondary wastewater treatment.
- Eliminates grease cap build-up in lift stations.
- Reduces grease build-up in mains.

DIRECTIONS FOR USE:

GREASE AWAY should be mixed at the rate of one pound with one gallon of warm water. Mix to form a slurry and let sit for 10-20 minutes before pouring into water.

TREATMENT SCHEDULE FOR LAGOONS AND PONDS:

The chart below assumes that the waters have been significantly fouled. For less-fouled waters, contact your sales representative for a treatment schedule.

Pounds of GREASE AWAY per Acre foot	Week	Frequency
3	First	Twice
2	Second	Twice
1	Third	Twice

For regular maintenance, use 1/2 pound per acre foot weekly.

GREASE AWAY

Heavy Grease – BOD Bio-Degrader
For Lagoons, Secondary Wastewater
Treatment and Wastewater
Collection Systems

UNITED C284

KEEP OUT OF REACH OF CHILDREN.

CAUTION

SEE SIDE PANEL FOR ADDITIONAL
PRECAUTIONARY STATEMENTS.

PRECAUCION AL USUARIO: Si usted no puede leer Ingles, pregunte a alguien que le traduzca esta etiqueta para usted entes de uso.

UNITED LABORATORIES, INC.

320 37th Avenue • St. Charles, IL 60174

1-800-323-2594 • www.unitedlabsinc.ca

SECONDARY TREATMENT:

One Pound per 100,000 GPD should be applied twice the first week; .5 pounds per 100,000 GPD should be applied twice the second and third week and .25 pounds per 100,000 GPD should be applied twice per week the fourth and fifth weeks.

The maintenance dose is .5 pounds twice per month per 100,000 GPD.

For Wastewater Collection Systems Lift Stations – .5 Pounds twice per week per 5' of diameter in the lift station, spread across the surface of the grease trap as a slurry until the grease cap is eliminated.

For Mains – .25 pounds per 100,000 GPD twice per week to control grease build-up in the pipe is recommended.

CAUTION:

Avoid inhalation of powder. Wash hands after use. Store in a cool dry place.

EMERGENCY AND FIRST AID PROCEDURES:

EYES: Flush with water for at least 15 minutes.

SKIN: Wash with soap and water. If irritation develops, seek medical attention.

INHALATION: Remove to fresh air. If difficulty in breathing develops, seek medical attention.

IF SWALLOWED: DO NOT INDUCE vomiting. Drink two glasses of water to dilute. If irritation develops, seek medical attention.

An MSDS for this product has been provided. Please read it carefully and follow all instructions when using or handling this product. Never reuse empty containers. Incompatible materials may adversely react.

HMS® CODE:

- 0=MINIMAL
- 1=SLIGHT
- 2=MODERATE
- 3=SERIOUS
- 4=SEVERE

HEALTH	0
FLAMMABILITY	0
REACTIVITY	0
PERSONAL PROTECTION	B

PERSONAL PROTECTION INDEX: Gloves and Glasses